



GENERAL NOTES AND INSTALLATION BY CONTRACTOR:

1. ALL WORK BY CONTRACTOR UNLESS SHOWN BY G.W.
2. FOR METER INSTALLATIONS WHICH VARY FROM THAT SHOWN, CONTACT G.W. ENGINEERING PRIOR TO EXCAVATING.
3. FOR EXISTING INLET SERVICES WITH NO CUT-OFF OR CURB STOP, IT IS THE CONTRACTOR'S RESPONSIBILITY TO EITHER CRIMP OR FREEZE THE EXISTING INLET SERVICE AND CUT IN A BRASS TEE. CONTRACTOR TO LEAVE OPEN FOR INSPECTION BY G.W. PRIOR TO BACKFILL.
4. CONTRACTOR MAY PROVIDE & INSTALL METER SETTERS MEETING G.W. SPECIFICATIONS. CONTACT G.W. ENGINEERING FOR LIST OF APPROVED METER SETTERS.
5. FINAL INSTALLATION SHALL BE SUCH THAT EACH METER CAN BE TURNED OFF INDIVIDUALLY.
6. NEW INLET PIPING & FITTINGS MUST BE EXPOSED FOR INSPECTION WHEN METERS ARE SET.
7. OUTLET PIPING CONSISTING OF THREADED FEMALE BRASS COUPLING, OUTLET SERVICE PIPE, AND BALL VALVE TO BE ASSEMBLED AND READY FOR INSTALLATION PRIOR TO G.W. ARRIVAL ON SITE.
8. NEW INLET SERVICE PIPING TO MATCH EXISTING INLET SERVICE PIPING.

METER SIZE	5/8"	1"
SPACE NEEDED BETWEEN FACE OF FEMALE COUPLING AND END OF PEX	"A"	9"
		12 1/2"



GreenvilleWater

5-8" & 1" TAP TO SERVICE

REVISION DATE:	02.08.2024
	(NOT TO SCALE)

DETAIL NO:	1-1
------------	-----

L:\Engg\DWG-SUPPORT\Detail\2023 Detail\5-8 & 1 Tap to Service_newtemplate.dwg