



2026 Water Quality Results (Monthly Averages) - This report provides results of monthly water quality testing at the Stovall Water Treatment Plant and the Adkins Water Treatment Plant. Additional water quality testing results can be found on the 2025 Consumer Confidence Report (CCR) located on the Greenville Water website at <https://www.greenvillewater.com/water-resources/water-quality>.

Parameter	Units	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	YTD Average	YTD Min	YTD Max
Total coliform	(P/A)	Absent	Absent	Absent										Absent	Absent	Absent
E. coli	(P/A)	Absent	Absent	Absent										Absent	Absent	Absent
Adenosine Triphosphate (ATP)	ME/ml	<100	<100	<100										<100	<100	<100
Total Chlorine	mg/L	3.1	3.2	3.2										3.2	3.1	3.2
pH	S.U.	7.6	7.6	7.5										7.6	7.5	7.6
Turbidity	NTU	0.04	0.03	0.04										0.04	0.03	0.04
Temperature	°C	16.5	13.9	16.1										15.5	13.9	16.5
Fluoride	mg/L	0.62	0.63	0.64										0.63	0.62	0.64
Chloride	mg/L	XXXXX	4.2	4.3										4.3	4.2	4.3
Bromide	mg/L	XXXXX	<0.050	<0.050										<0.050	<0.050	<0.050
ortho-PO4	mg/L	0.57	0.58	0.60										0.58	0.57	0.60
Total-PO4	mg/L	0.74	0.71	0.69										0.71	0.69	0.74
Sulfate	mg/L	XXXXX	3.8	3.9										3.9	3.8	3.9
Nitrite-N	mg/L	XXXXX	<0.010	0.02										<0.010	<0.010	0.020
Nitrate-N	mg/L	XXXXX	0.23	0.24										0.24	0.23	0.24
Total Alkalinity	mg/L	10	8.9	8.3										9.1	8.3	10.0
Total Dissolved Solids (TDS)	mg/L	27	39	42										36.0	27.0	42.0
Calcium	mg/L	XXXXX	XXXXX	1.3										1.3	1.3	1.3
Magnesium	mg/L	XXXXX	XXXXX	0.52										0.52	0.52	0.52
Sodium	mg/L	XXXXX	XXXXX	6										6.0	6.0	6.0
Potassium	mg/L	XXXXX	XXXXX	0.82										0.82	0.82	0.82
Total Ammonia	mg/L	0.69	0.77	0.72										0.73	0.69	0.77
Free Ammonia	mg/L	<0.20	<0.20	<0.20										<0.20	<0.20	<0.20
Total Hardness	mg/L	XXXXX	XXXXX	5.4										5.4	5.4	5.4
Iron	mg/L	<0.050	XXXXX	<0.050										<0.050	<0.050	<0.050
Manganese	mg/L	<0.010	XXXXX	<0.10										<0.010	<0.010	<0.10
Copper	mg/L	XXXXX	XXXXX	0.006										0.006	0.006	0.006
Lead	mg/L	XXXXX	XXXXX	<0.002										<0.002	<0.002	<0.002
Aluminum	mg/L	<0.050	<0.050	<0.050										<0.050	<0.050	<0.050
Total Organic Carbon (TOC)	mg/L	0.76	0.75	0.62										0.71	0.62	0.76
Conductivity	uS/cm	45	47	43										45	43	47

<100 = 50 for calculating average

Abbreviations:
 P/A = Present/Absent
 mg/L - milligrams/liter (ppm)
 ME/ml = microbial equivalent per milliliter
 uS/cm = microSiemens/centimeter
 < = less than
 > = greater than

Hardness Scale
 < 17.1 mg/L = soft
 17.1 to 60 mg/L = slightly hard
 60 to 120 mg/L = moderately hard
 > 120 mg/L = hard

Notes:
 Turbidity from - Operator Daily Sheets
 Finished Water Quality Report (1st Monday of month or equivalent)