GreenvilleWater

2026 Water Quality Results (Monthly Averages) - This report provides results of monthly water quality testing at the Stovall Water Treatment Plant and the Adkins Water Treatment Plant. Additional water quality testing results can be found on the 2025 Consumer Confidence Report (CCR) located on the Greenville Water website at https://www.greenvillewater.com/water-resources/water-quality.

Parameter	Units	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	YTD Average	YTD Min	YTD Max
Total coliform	(P/A)	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent	Absent
E. coli	(P/A)	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					Absent	Absent	Absent
Adenosine Triphosphate (ATP)	ME/ml	<100	<100	<100	<100	<100	<100	<100	<100					<100	<100	<100
Total Chlorine	mg/L	3.1	3.2	3.2	2.9	3.1	2.8	3.1	3.0					3.1	2.8	3.2
pH	S.U.	7.6	7.6	7.5	7.9	7.7	7.6	7.6	7.5					7.6	7.5	7.9
Turbidity	NTU	0.04	0.03	0.04	0.04	0.04	0.04	0.05	0.04					0.04	0.03	0.05
Temperature	°C	16.5	13.9	16.1	19.4	21.3	23.4	26.4	26.6					20.5	13.9	26.6
Fluoride	mg/L	0.62	0.63	0.64	0.66	0.66	0.69	0.73	0.74					0.67	0.62	0.74
Chloride	mg/L	XXXXX	4.2	4.3	4.3	4.7	4.4	4.9	4.6					4.5	4.2	4.9
Bromide	mg/L	XXXXX	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050					<0.050	<0.050	<0.050
ortho-PO4	mg/L	0.57	0.58	0.60	0.62	0.62	0.64	0.65	0.64					0.62	0.57	0.65
Total-PO4	mg/L	0.74	0.71	0.69	0.72	0.80	0.82	0.82	0.74					0.76	0.69	0.82
Sulfate	mg/L	XXXXX	3.8	3.9	3.9	4.2	4.0	4.0	4.2					4.0	3.8	4.2
Nitrite-N	mg/L	XXXXX	<0.010	0.02	0.04	0.03	<0.010	<0.010	<0.010					<0.010	<0.010	0.040
Nitrate-N	mg/L	XXXXX	0.23	0.24	0.23	0.16	0.14	0.09	0.13					0.17	0.23	0.24
Total Alkalinity	mg/L	10	8.9	8.3	8.7	8.3	8.5	9.3	9.2					8.9	8.3	10.0
Total Dissolved Solids (TDS)	mg/L	27	39	42	56	60	43	19	38					40.5	19.0	60.0
Calcium	mg/L	XXXXX	XXXXX	1.3	1.2	1.3	XXXXX	XXXXX	XXXXX					1.3	1.2	1.3
Magnesium	mg/L	XXXXX	XXXXX	0.52	0.47	0.58	XXXXX	XXXXX	XXXXX					0.52	0.47	0.58
Sodium	mg/L	XXXXX	XXXXX	6.0	6.0	6.2	XXXXX	XXXXX	XXXXX					6.1	6.0	6.2
Potassium	mg/L	XXXXX	XXXXX	0.82	0.75	0.84	XXXXX	XXXXX	XXXXX					0.80	0.75	0.84
Total Ammonia	mg/L	0.69	0.77	0.72	0.60	0.64	0.61	0.66	0.70					0.67	0.60	0.77
Free Ammonia	mg/L	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20	<0.20					<0.20	<0.20	<0.20
Total Hardness	mg/L	XXXXX	XXXXX	5.4	4.9	6.7	XXXXX	XXXXX	XXXXX					5.7	4.9	6.7
Iron	mg/L	<0.050	XXXXX	<0.050	<0.050	<0.050	XXXXX	<0.050	<0.050					<0.050	<0.050	<0.050
Manganese	mg/L	<0.010	XXXXX	<0.10	<0.10	<0.10	XXXXX	0.10	<0.10					<0.010	<0.010	0.10
Copper	mg/L	XXXXX	XXXXX	0.006	0.006	0.008	XXXXX	XXXXX	XXXXX					0.006	0.006	0.006
Lead	mg/L	XXXXX	XXXXX	<0.002	<0.002	<0.002	XXXXX	XXXXX	XXXXX					<0.002	<0.002	<0.002
Aluminum	mg/L	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050	<0.050					<0.050	<0.050	<0.050
Total Organic Carbon (TOC)	mg/L	0.76	0.75	0.62	0.62	0.72	0.72	0.78	0.75					0.72	0.62	0.78
Conductivity	uS/cm	45	47	43	43	46	46	49	50					46	43	50

Abbreviations:

P/A = Present/Absent
mg/L - milligrams/liter (ppm)
ME/ml = microbial equivalent per milliliter
uS/cm = microSiemens/centimeter
< = less than
> = greater than

Hardness Scale

< 17.1 mg/L = soft
17.1 to 60 mg/L = slightly hard
60 to 120 mg/L = moderately hard
> 120 mg/L = hard