



2024 Water Quality Results (Monthly Averages)

This report provides results of monthly water quality testing at the Stovall Water Treatment Plant and the Adkins Water Treatment Plant.
 Additional water quality testing results can be found on the 2022 Consumer Confidence Report (CCR) located on the Greenville Water website at:
www.greenvillewater.com/documents/CCR-05.2023.pdf

Parameter	Units	January	February	March	April	May	June	July	August	September	October	November	December	YTD Average	YTD Min	YTD Max
Total coliform	(P/A)	Absent												Absent	Absent	Absent
E. coli	(P/A)	Absent												Absent	Absent	Absent
Total Chlorine	mg/L	2.8												2.8	2.8	2.8
pH	S.U.	7.5												7.5	7.5	7.5
Turbidity	NTU	0.03												0.03	0.03	0.03
Temperature	°C	16.6												16.6	16.6	16.6
Fluoride	mg/L	0.64												0.64	0.64	0.64
Chloride	mg/L	4.4												4.4	4.4	4.4
Bromide	mg/L	<0.050												<0.050	<0.050	<0.050
ortho-PO4	mg/L	0.57												0.57	0.57	0.57
Total-PO4	mg/L	0.79												0.79	0.79	0.79
Sulfate	mg/L	4.1												4.1	4.1	4.1
Nitrite-N	mg/L	<0.050												<0.050	<0.050	<0.050
Nitrate-N	mg/L	0.06												0.06	0.06	0.06
Alkalinity	mg/L	10.0												10.0	10.0	10.0
Total Dissolved Solids (TDS)	mg/L	23												23.0	23.0	23.0
Calcium	mg/L	1.3												1.3	1.3	1.3
Magnesium	mg/L	0.58												0.58	0.58	0.58
Sodium	mg/L	6.5												6.5	6.5	6.5
Potassium	mg/L	0.77												0.77	0.77	0.77
Total Ammonia	mg/L	0.69												0.69	0.69	0.69
Free Ammonia	mg/L	0.17												0.17	0.17	0.17
Total Hardness	mg/L	5.6												5.6	5.6	5.6
Iron	mg/L	<0.050												<0.050	<0.050	<0.050
Manganese	mg/L	<0.010												<0.010	<0.010	<0.010
Copper	mg/L	<0.010												<0.010	<0.010	<0.010
Lead	mg/L	<0.005												<0.005	<0.005	<0.005
Aluminum	mg/L	<0.050												<0.050	<0.050	<0.050
Total Organic Carbon (TOC)	mg/L	0.69												0.69	0.69	0.69
Conductivity	uS/cm	44												44	44	44

ABBREVIATIONS:								HARDNESS SCALE:					
(P/A)	Present/Absent	S.U.	Standard Units	ME/ml	microbial equivalent per milliliter	°C	degrees Celsius	<	less than	< 17.1 mg/L	soft	60 to 120 mg/L	moderately hard
mg/L	milligrams/liter (ppm)	NTU	Nephelometric Turbidity Units	uS/cm	microSiemens/centimeter	*	Not run in January	>	greater than	17.1 to 60 mg/L	slightly hard	> 120 mg/L	hard