



**APPROVED MATERIAL SUPPLIERS:**

GIBSON SUPPLY, TEC UTILITIES SUPPLY, CORE & MAIN, FERGUSON WATERWORKS, FORTLINE WATERWORKS, HAYES PIPE SUPPLY, CONSOLIDATED PIPE & SUPPLY, STALINE WATERWORKS, INC.

**GENERAL NOTES AND INSTALLATION BY CONTRACTOR:**

- ALL EXCAVATION TO BE DONE BY CONTRACTOR.
- APPROXIMATE SIZE OF HOLE WHERE TAP IS MADE IS 5' X 5' (6" BEHIND AND UNDER MAIN). HOLE TO BE WIDER AND SHORED WHEN MAIN IS DEEPER THAN 5'. - HOLE FOR 5/8" AND 1" METER BOX 30" WIDE X 42" LONG X 21" DEEP.
- SERVICE LINE MUST HAVE 36" COVER (MIN.) UNDER ROADSIDE DITCH - METER NOT TO BE PLACED IN DRIVEWAY.
- OSHA APPROVED LADDER TO BE PROVIDED BY CONTRACTOR IN EXCAVATION DEEPER THAN 5' WITH OSHA APPROVED TRENCH BOX OR SHORING.
- OUTLET PIPING CONSISTING OF THREADED BRASS FEMALE COUPLING, 18" OF OUTLET SERVICE PIPE, BALL VALVE, METER SETTER, AND ACCESS BOX TO BE ASSEMBLED BY CONTRACTOR AND READY FOR METER INSTALLATION PRIOR TO G.W. ARRIVAL TO SITE.
- METER BOX TO BE CLEANED OF DIRT AND DEBRIS TO THE BOTTOM OF THE METER SETTER.
- METERS FOR COMMERCIAL IRRIGATION SERVICE REQUIRE SCDES APPROVED DCVA BACKFLOW PREVENTER BEHIND METER.

APPROVED MATERIALS			APPROVED MATERIALS		
TYPE	MANUFACTURER	PART NUMBER	TYPE	MANUFACTURER	PART NUMBER
AWWA x CTS CORP STOP (BALL STYLE, 300PSI)	A.Y. MCDONALD	74701BG	COPPER METER SETTER	A.Y. MCDONALD	720-209WDM 33x995
	FORD	FB1000-3-G-NL			720-410WDM 44x992
		MUELLER		B25008N	FORD
CTS x FEMALE CURB STOP (BALL STYLE, 300PSI)	A.Y. MCDONALD	76102G		MUELLER	B-2404N-6A
	FORD	B41-333-NL		B-2404N-2AN	
		MUELLER		B41-444-NL	A.Y. MCDONALD
FEMALE FLARED x CTS ADAPTER	A.Y. MCDONALD	74755G	COPPER SETTER SWIVEL (MALE)	FORD	CSS8-33-NL
	FORD	C04-xx-G-NL		MUELLER	H14223N
	MUELLER	H15071N	METER BOX (18-INCH)	CARSON	2200-18 BLACK MSH 1
CTS x MALE ADAPTER	A.Y. MCDONALD	74753G	METER BOX LID (12 1/2-INCH)	CARSON	8-HOLE w/GREENVILLE WATER LOGO FOR 2200-18
	FORD	C84-xx-G-NL			
MUELLER	H15428N				



GreenvilleWater

**TYPICAL METER INSTALLATION -  
5/8"x3/4" & 1"  
TAP AND METER SET BY GW**

REVISION DATE:

02/10/2025

(NOT TO SCALE)

DETAIL NO:

1