



APPROVED MATERIAL SUPPLIERS:

GIBSON SUPPLY, TEC UTILITIES SUPPLY, CORE & MAIN, FERGUSON WATERWORKS, FORTILINE WATERWORKS, HAYES PIPE SUPPLY, CONSOLIDATED PIPE & SUPPLY, STALINE WATERWORKS, INC.

COMPRESSION FITTINGS FOR PEX: BRASS – FORD, MUELLER, OR A.Y. MCDONALD

GENERAL NOTES AND INSTALLATION BY CONTRACTOR:

1. ALL WORK TO BE DONE BY CONTRACTOR UNLESS OTHERWISE SHOWN
2. MINIMUM TRENCH WIDTH 12". COMPACTION REQUIRED.
3. SERVICE LINE MUST HAVE 36" COVER (MIN.) UNDER ROADSIDE DITCH - METER NOT TO BE PLACED IN DRIVEWAY. NO COUPLINGS SHALL BE PERMITTED IN ADDITION TO BRASS FEMALE COMPRESSION FITTING AT TAP LOCATION.
5. OUTLET PIPING CONSISTING OF THREADED BRASS FEMALE COUPLING, 4' OF OUTLET SERVICE PIPE, AND BALL VALVE TO BE ASSEMBLED BY PLUMBER AND READY FOR INSTALLATION PRIOR TO G.W. ARRIVAL TO SITE FOR METER SETTER INSTALLATION.
6. CONTRACTOR TO BLOW OFF SERVICE LINE AND CLOSE CURB STOP.
7. CONTRACTOR SHALL CALL G.W. ENGINEERING (864-241-6100) TO REPORT WHEN READY FOR INSPECTION OR FOR ASSISTANCE IF UNUSUAL CONDITIONS EXIST.

APPROVED MATERIALS		
TYPE	MANUFACTURER	PART NUMBER
CTS CORP STOP (BALL STYLE, 300PSI)	A.Y. MCDONALD	74701BG
	FORD	FB-1000-3-G-NL
	FORD	FB-1000-4-G-NL
CTS x FEMALE CURB STOP (BALL STYLE, 300PSI)	MUELLER	B25008N
	A.Y. MCDONALD	76102WG
	FORD	B11-333-NL
	FORD	B11-444-NL
	MUELLER	G25172N



GreenvilleWater

**TYPICAL TAP-TO-CURB INSTALLATION -
3/4" & 1"**

REVISION DATE:	DETAIL NO:
9.11.2024	13
(NOT TO SCALE)	