



**NOTES:**

1. FILL SAMPLE PIPING w/HEAVILY CHLORINATED WATER WHILE MAINS ARE BEING STERILIZED. (MIX 2 TABLESPOONS OF H.T.H. PER GALLON WATER IN SAMPLE PIPING); CONTACT TIME TO BE 30 MINUTES (minimum)
2. WATER MUST BE RUNNING FROM BALL VALVE (SLOWLY) FOR 30 MINUTES PRIOR TO SAMPLE



GreenvilleWater

2" BLOW-OFF PIPING  
(FOR SAMPLING)

REVISED: 08/30/2013

L:\ENGG\DWG-SUPPORT\DETAILS\BLOW-OFF.DWG