

COMMISSIONERS OF PUBLIC WORKS
OF THE CITY OF GREENVILLE
SOUTH CAROLINA

GREENVILLE WATER

CONSTRUCTION SPECIFICATIONS

FOR

WATER MAINS

ADDENDUM NO. 2

July 9, 2015

1. Replace Section 5-5.01 with the following:

5-5.01. Mechanical Joint Restrained Joints – As an alternative to standard restrained joints, EBAA Iron “Megalugs” Series 1100 or 1700, Star Pipe Products “Stargrip” Series 3000 or Tyler Union “TUF Grip” Series 1000, without substitute, may be used for 6-inch through 20-inch ductile iron pipe. The locations for these types of joints shall be acceptable to Engineer.

End of Addendum No. 2