



NOTE:  
 REQUIRED AS DIRECTED ON ALL WATER MAINS 10" AND LARGER.  
 ALL EXCAVATING TO BE DONE BY CONTRACTOR.  
 APPROXIMATE SIZE OF HOLE WHERE TAP IS MADE IS 3' X 5' (6" BEHIND AND UNDER MAIN WITH REMAINDER OF EXCAVATION ON TAP SIDE OF MAIN)  
 PLACE FOR AIR RELEASE BOX 3' X 3' X 21" DEEP.  
 SERVICE LINE 36" MIN. COVER UNDER ROADSIDE DITCH.  
 BOX NOT TO BE PLACED IN DRIVEWAY.  
 CONTRACTOR SHOULD CALL G.W. ENGINEERING TO REPORT WHEN READY FOR TAP TO BE MADE AND AIR RELEASE VALVE TO BE SET.



GreenvilleWater

AIR RELEASE VALVE

(TYPICAL DETAIL)

REVISED: 9/1/2015