

COMMISSIONERS OF PUBLIC WORKS  
OF THE CITY OF GREENVILLE  
SOUTH CAROLINA

GREENVILLE WATER

---

**CONSTRUCTION SPECIFICATIONS**

**FOR**

**WATER MAINS**

---

**ADDENDUM NO. 1**

August 31, 2017

1. Replace Section 5-8 with the following:

5-8. FIRE HYDRANTS - All fire hydrants shall be 4-1/2-inch nominal valve opening, National Standard Nozzle Threads and Operating Details, Two 2-1/2-inch nozzles and One 4-1/2-inch nozzle, 6-inch M.J. Inlet Connection or ALPHA end, depth of bury to suit field conditions, painted highway safety yellow, breakable ground flange and conforming to AWWA C502. Check with Engineering for direction of opening. See Typical Hydrant Installation detail.

5-8.01. APPROVED FIRE HYDRANTS:

<u>NAME</u>	<u>CATALOG #</u>
1. American-Darling	MK 73-5
2. Mueller Super Centurion 250	A-421

End of Addendum No. 1