

COMMISSIONERS OF PUBLIC WORKS
OF THE CITY OF GREENVILLE
SOUTH CAROLINA

GREENVILLE WATER

CONSTRUCTION SPECIFICATIONS
FOR
WATER MAINS

ADDENDUM NO. 2

December 7, 2017

1. Replace Section 5-3.04 with the following:

5-3.04. HDPE Pipe – 3/4-inch to 2-inch CTS, rated 250 psi with 12 gauge tracer wire attached by the HDPE pipe manufacturer. HDPE pipe with tracer wire attached by party other than the HDPE pipe manufacturer will not be accepted. Provide additional wire as needed to connect to adjacent metal piping or valves.

2. Replace Section 5-3.05 with the following:

5-3.05. PEXa Pipe – 3/4-inch to 2-inch CTS, rated 200 psi working pressure, meeting AWWA C904 standards. Pipe shall have an ultraviolet light (UV) shield with a minimum recommended UV exposure time of one year when tested in accordance with ASTM F2657. Manufacturer shall warrant the product for 25 years. A 12 gauge tracer wire shall be attached by the PEXa pipe manufacturer. PEXa pipe with tracer wire attached by party other than the PEXa pipe manufacturer will not be accepted. Provide additional wire as needed to connect to adjacent metal piping or valves.

End of Addendum No. 2