



NOTES:

- 1) FIRE HYDRANT TO BE INSTALLED PLUMB.
- 2) FIRE HYDRANT TO BE 3-WAY WITH DEPTH OF BURY TO BE DETERMINED BY FIELD CONDITIONS.
- 3) HYDRANT LEAD TO BE PRESSURE CLASS 350 DUCTILE IRON.
- 4) WHEN FIRE HYDRANT RESTRAINT BY RODDING NECESSARY, TWO 3/4" \varnothing ALLTHREAD RODS REQUIRED AS A MINIMUM.
- 5) ONLY USE MUELLER OR AFC HYDRANTS.



GreenvilleWater

TYPICAL HYDRANT INSTALLATION

REVISED: 11/30/2018