



USE FORD OR MUELLER BRASS  
CTS COMPRESSION FITTINGS FOR PEX

GENERAL NOTES:

1. CONTRACTOR TO REMOVE EXISTING METER BOX FOR G.W. TO RECLAIM AND EXCAVATE 30" WIDE X 42" LONG X 18" DEEP FOR INSTALLATION OF TANDEM METER BOX.
2. FOR EXISTING INLET SERVICES WITH NO CUT-OFF OR CURB STOP, IT IS THE CONTRACTOR'S RESPONSIBILITY TO EITHER CRIMP OR FREEZE THE EXISTING INLET SERVICE & CUT IN BRASS CURB STOP AND BRASS TEE. CONTRACTOR TO LEAVE OPEN FOR INSPECTION WITH BACKFILL TO OCCUR AFTER INSTALLATION.
3. ALL FITTINGS ARE TO BE PROVIDED AND INSTALLED BY THE CONTRACTOR (PRIOR TO G.W. ARRIVAL) WITH THE EXCEPTION OF METER(S) & METER BOX.
4. NEW INLET PIPING & FITTINGS MUST BE EXPOSED FOR INSPECTION WHEN METERS ARE SET.
5. THE CONTRACTOR MAY PROVIDE & INSTALL METER SETTERS MEETING G.W. SPECIFICATIONS. (CONTACT G.W. ENGINEERING DEPT. FOR APPROVED LIST).
6. FOR IRRIGATION METER INSTALLATIONS WHICH VARY FROM THAT SHOWN, CONTACT G.W. PRIOR TO EXCAVATING.
7. METER BOX TO BE CLEANED OF DIRT AND DEBRIS TO THE BOTTOM OF THE METER SETTER.

METER SIZE	5/8"
SPACE NEEDED BETWEEN FACE OF FEMALE COUPLING AND END OF BRASS FITTINGS	"A" 9"



GreenvilleWater

TYPICAL RESIDENTIAL TANDEM 5/8" DOMESTIC AND IRRIGATION METER INSTALLATION BY CONTRACTOR

REVISED DATE: JUNE, 2021

L:\Engg\DWG-SUPPORT\Details\GroundsMeter\_Tandem.dwg