

- 2. APPROXIMATE SIZE OF HOLE WHERE TAP IS MADE IS 5' X 5' (6" BEHIND AND UNDER MAIN). HOLE TO BE WIDER AND SHORED WHEN MAIN IS DEEPER THAN 5'. -HOLE FOR 5/8" AND 1" METER BOX 30" WIDE X 42" LONG X 21" DEEP.
- 3. SERVICE LINE MUST HAVE 36" COVER (MIN.) UNDER ROADSIDE DITCH. METER NOT TO BE PLACED IN DRIVEWAY.
- 4. OSHA APPROVED LADDER TO BE PROVIDED BY CONTRACTOR IN EXCAVATION DEEPER THAN 5' WITH OSHA APPROVED TRENCH BOX OR SHORING.
- 5. PLUMBER SHOULD CALL G.W. ENGINEERING (241-6100) TO REPORT WHEN READY FOR METER TO BE SET OR FOR ASSISTANCE IF UNUSUAL CONDITIONS EXIST.
- 6. OUTLET PIPING CONSISTING OF THREADED BRASS FEMALE COUPLING, 18" OF OUTLET SERVICE PIPE, BALL VALVE & ACCESS BOX TO BE ASSEMBLED BY PLUMBER AND READY FOR INSTALLATION PRIOR TO G.W. ARRIVAL TO SITE.
- 7. USE FORD OR MUELLER BRASS COMPRESSION FITTINGS FOR PEX.
- 8. CURB STOPS 1" FORD Z41-444-G-NL, 3/4" Z41-333-G-NL OR MUELLER H15172N.
- 9. METER BOX TO BE CLEANED OF DIRT AND DEBRIS TO THE BOTTOM OF THE METER SETTER.



GreenvilleWater

TYPICAL METER INSTALLATION TAPS BY GREENVILLE WATER 3/4" & 1"

REVISED: MAY, 2022

SIGNATURE _____