



USE FORD OR MUELLER BRASS
CTS COMPRESSION FITTINGS FOR PEX

METER SIZE	5/8"
SPACE NEEDED BETWEEN FACE OF FEMALE COUPLING AND END OF BRASS FITTINGS	"A" 9"

GENERAL NOTES:

1. FOR IRRIGATION METER INSTALLATIONS WHICH VARY FROM THAT SHOWN, CONTACT G.W. PRIOR TO EXCAVATING.
2. IRRIGATION SYSTEM PIPING TO BE STUBBED TO WITHIN 18" OF PROPOSED METER BOX LOCATION (BY CONTRACTOR) FOR G.W. TO CONNECT TO.
3. IF EXISTING METER IS IN SIDEWALK, DRIVEWAY OR TREE, IT MUST BE RELOCATED INTO UNENCUMBERED AREA BY PROPERTY OWNER, PRIOR TO IRRIGATION METER INSTALLATION BY G.W.



GreenvilleWater

TYPICAL RESIDENTIAL TANDEM 5/8" DOMESTIC AND IRRIGATION METER INSTALLATION BY GW

REVISED DATE: MAY, 2022

SIGNATURE _____